



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

***EX301a, EX302a, EX303a. Type Y Pressurizing Systems.***

Available with EXV1 or EXV2 Relief Vent.

APY / I,II / 1 / \* / T6

a\* = Pressure Switch 0 = No (Groups ABCDFG), 1 = Yes (Groups CDFG).

***EX300a, EX301a, EX302a, EX303a. Type Z Pressurizing Systems.***

Available with EXV1 or EXV2 Relief Vent.

APZ / I,II / 2 / \* / T6

a\* = Pressure Switch 0 = No (Groups ABCDFG), 1 = Yes (Groups CDFG).

### Equipment Ratings:

The EX300 Series Pressurization Systems are rated for control of a Type Y Pressurized System for use in Class I and II, Division 1, and Type Z Pressurization System for use in Class I and II, Division 2 Hazardous (Classified) Locations.

### FM Approved for:

ExLoc Instruments Inc.  
Warrenton, VA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3620	1989
ANSI/NFPA-496	1993

Original Project ID: 3028025

Approval Granted: November 16, 2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
Andrew Lozinski  
Technical Team Manager

  
Date