

(1) **Certificate of Conformity**

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres – Directive 2014/34/EU

(3) Certificate Number:

EPS 19 ATEX 1 248 X

Revision 1

(4) Equipment: BEx2-Remote IO, Type 24*****

(5) Manufacturer: BEx-Solution GmbH

(6) Address: Lange Straße 99
76199 Karlsruhe
Germany

(7) This equipment and any acceptable variation thereto are specified in the schedule to this Certificate of Conformity and the documents therein referred to.

(8) Bureau Veritas Consumer Products Services Germany GmbH certifies based on a voluntary assessment that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II of the Directive 2014/34/EU. The examination and test results are recorded in the confidential documentation under the reference number 19TH0487.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018

EN 60079-7:2018


EN 60079-11:2012

EN 60079-18/AC:2018

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This Certificate of Conformity relates only to the design and the construction of the specified equipment in accordance with Directive 2014/34/EU. Further requirements of this Directive apply to the manufacture and supply of this equipment. Those requirements are not covered by this certificate.

(12) The marking of the equipment shall include the following:

 II 3(1) G Ex ec mc [ia Ga] IIC T4 Gc

 II (1) D [Ex ia Da] IIIC



Certification department of explosion protection

Hamburg, 2020-02-25



H. Schaffer

(13)

Annexe

(14) **Certificate of Conformity EPS 19 ATEX 1 248 X**

Revision 1

(15) Description of equipment:

The equipment is a Remote IO system which isolates the non-intrinsically safe input circuits and the supply circuits from the intrinsically safe output circuits. It provides a transfer of non-intrinsically safe input signals to intrinsically safe output signals. The input circuits are suitable to be located in zone 2 (EPL Gc) and the output circuits are suitable to be connected to other intrinsically safe circuits in zone 0 (EPL Ga). The equipment is also suitable to be located outside a hazardous area and the output circuits to be connected to other intrinsically safe circuits in zone 20 (EPL Da). The Remote IO system includes a variety of different modules, differing in the bus type to be connected. The equipment has to be installed in a suitable housing (see special conditions).

Electrical data:

$U_m = 30 \text{ V DC}$ (Terminals X9 / X10)

Terminal block X1 to X8 (output parameters of each clamp, clamps are not allowed to be combined):

Clamp (26 V):
 $U_o = 26 \text{ V d.c.}$
 $I_o = 82 \text{ mA}$
 $P_o = 533 \text{ mW}$

Group IIC				
L_o	3 mH	1 mH	0.5 mH	0 mH
C_o	42 nF	62 nF	78 nF	99 nF
Group IIB / III				
L_o	20 mH	2 mH	0.5 mH	0 mH
C_o	350 nF	350 nF	490 nF	770 nF

Clamp (9.6 V):
 $U_o = 9.6 \text{ V d.c.}$
 $I_o = 31 \text{ mA}$
 $P_o = 75 \text{ mW}$

Group IIC				
L_o	49 mH	10 mH	1 mH	0 mH
C_o	310 nF	640 nF	1.1 μF	3.6 μF
Group IIB / III				
L_o	100 mH	10 mH	1 mH	0 mH
C_o	2 μF	3.6 μF	6.1 μF	26 μF

Clamp (GND): Galvanically separated from input GND

	Type: 24200*00	Type: 24200*01	Type: 24200*02
Clamp 1	$U_o = 26 \text{ V d.c.}$	$U_o = 26 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$
Clamp 2	GND	GND	GND
Clamp 3	$U_o = 26 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$
Clamp 4	GND	GND	GND
Clamp 5	$U_o = 9.6 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$
Clamp 6	GND	GND	GND
Clamp 7	$U_o = 26 \text{ V d.c.}$	$U_o = 26 \text{ V d.c.}$	$U_o = 9.6 \text{ V d.c.}$
Clamp 8	GND	GND	GND

Page 2 of 3

Certificates without signature and seal are void. This certificate is allowed to be distributed only if not modified. Extracts or modifications must be authorized by Bureau Veritas Consumer Products Services Germany GmbH. EPS 19 ATEX 1 248 X, Revision 1.

(16) Reference number: 19TH0487

(17) Schedule of Limitations:

The BEx2-Remote IO of the types 2420010*, 2420020*, 2420030*, 2420040*, 2420050* and 2420060* have to be installed in a suitable housing according to the directive 2014/34/EU and the IECEx-Scheme in such a way, that a degree of protection of at least IP 54 is reached.

The non-intrinsically safe terminals of the equipment (terminals X9 and X10) shall be supplied by a source providing SELV output circuit or conforming to IEC 61010 or IEC 60950 (Um=30V DC).

(18) Essential health and safety requirements:

Met by standards.

Certification department of explosion protection

Hamburg, 2020-02-25

