

CERTIFICATE OF COMPLIANCE

Certificate Number 20190610-E222308
Report Reference E222308-20190601
Issue Date 2019-JUNE-10

Issued to: G M INTERNATIONAL S R L
Via G. Mameli, 53-55
20852 Villasanta Mb ITALY

**This certificate confirms that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS
LOCATIONS

PROCESS CONTROL EQUIPMENT FOR USE IN ZONE
CLASSIFIED HAZARDOUS LOCATIONS

Refer addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

Refer addendum page

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190610-E222308
Report Reference E222308-20190601
Issue Date 2019-JUNE-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

USL, CNL – Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C and D; Class I, Zone 2, AEx nA [ia Ga] IIC T4 Gc; Ex nA [ia Ga] IIC T4 Gc X, Hazardous Locations.

Models D5072, followed by S or D, may be followed by “-087”, “-096” or “-099”, providing intrinsically safe outputs for use in
Class I, Division 1, Groups A, B, C, and D;
Class II, Division 1, Groups E, F, and G;
Class III, Division 1;
Class I, Zone 0, Group IIC and
Zone 20, Group IIC, Hazardous Locations when installed per Control Drawing no. ISM0282.

Standards:

UL 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
UL 913, Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 60079-0, Explosive Atmospheres – Part 0: Equipment - General Requirements
UL 60079-11, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
UL 60079-15, Explosive Atmospheres – Part 15: Equipment Protection by Type of Protection “n”
CAN/CSA C22.2 No. 61010-1-12, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
CSA C22.2 NO.213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No.60079-0:15, Explosive Atmospheres – Part 0: Equipment - General Requirements
CAN/CSA C22.2 No.60079-11:14, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
CAN/CSA C22.2 No.60079-15:16, Explosive Atmospheres – Part 15: Equipment Protection by Type of Protection “n”



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

