



Iss.	3	Date	07.07 2014	Modification	Length (behind panel) was 74	Ckd.	.	Appd.	.
Iss.	4	Date	17.12 2014	Modification	Added note to skip issue 2.	Ckd.	.	Appd.	.
<p><b>BEKA associates</b> Hitchin England company confidential, copyright reserved.</p>									
Iss.	5	Date	10.05 2017	Modification	CRN1652: Panel cut-out updated. CRN1617 Rubber cap added.	Ckd.		Appd.	



#### VIEW ON ARROW A (REAR PANEL DETAILS)


TERMINAL BLOCKS  
ARE REMOVABLE



#### TERMINAL CONNECTIONS:


##### OPTION TERMINALS (WHEN OPTION FITTED):

##### BACKLIGHT




SEPARATELY  
POWERED  
LOOP POWERED  
COMMON

##### ALARMS



ALARM 1 ALARM 2

##### UNIT TERMINALS




4/20mA

TERMINALS 2 & 4 ARE  
INTERNALLY LINKED FOR  
JOINING RETURN WIRES

#### INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)
- 4 FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.

BEKA BEZEL



Title

CUSTOMER DRAWING for  
BA327E-SS 5 DIGIT I.S. INDICATOR  
IN PANEL MOUNTING ENCLOSURE

Drawn

RC

Checked

.

Scale

NTS

Drawing No.

CD327E-SS