



Iss.	1	Date	01.12.2011	Modification		Ckd.	AMH	Appd.	AC
Iss.		Date		Modification		Ckd.		Appd.	
BEKA associates Hitchin England company confidential, copyright reserved.									




THIRD ANGLE PROJECTION

DIMENSIONS IN mm

DO NOT SCALE




VIEW ON ARROW A
(REAR PANEL DETAILS)



TERMINAL CONNECTIONS:

OPTION TERMINALS (WHEN OPTION FITTED):



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

PANEL CUTOUT:

DIN 43 700: $92^{+0.8}_{-0} \times 45^{+0.6}_{-0}$

FOR IP66: $90^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$

Title
CUSTOMER DRAWING for
BA527E 5 DIGIT INDICATOR
IN PANEL MOUNTING ENCLOSURE

Drawn RC	Checked AMH	Scale NTS
Drawing No. CD527E		