




Appd.	
Ckd.	
Modification	
Date	
Iss.	
BEKA associates Hitchin England company confidential, copyright reserved.	
Appd.	
Ckd.	
Modification	
Date	24.11 2011
Iss.	1




TERMINAL CONNECTIONS:



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)



Title		Drawn	Checked	Scale
CUSTOMER DRAWING for BA558E LOOP POWERED RATE TOTALISER IN PANEL MOUNTING ENCLOSURE		RC	.	NTS
		Drawing No. CD558E		