

Iss.	1	Date	20.07 2017	Modification	.	Ckd.	.	Appd.	.
Iss.		Date		Modification		Ckd.		Appd.	
<div> <div>BEKA</div> <div>associates</div> <div>Hitchin England</div> </div> <div>company confidential, copyright reserved.</div>									

THIRD ANGLE PROJECTION

DIMENSIONS IN mm

DO NOT SCALE

144

72

DISPLAY HEIGHT 20mm

TOUGHENED GLASS WINDOW

11

84

STATIC DISSIPATIVE MODIFIED PPO BEZEL

NEOPRENE GASKET

ALUMINIUM ENCLOSURE

PRODUCT LABEL

SERIAL No. (& TAG LEGEND IF FITTED)

4 SCREW CLAMPS

CURRENT LOOP INPUT

OPTIONAL ALARM TERMINALS

SENSOR INPUT TERMINAL

VIEW ON ARROW A (REAR PANEL DETAILS)

TERMINAL CONNECTIONS:

ALARM 1

ALARM 2

CASE

Input

X DO NOT USE

INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL.
- 3 MAXIMUM RECOMMENDED TIGHTENING TORQUE 22cNm (1.95lbf.in)

PANEL CUTOUT:

DIN 43 700: $138^{+1.0}_{-0}$ x $68^{+0.7}_{-0}$

FOR IP65: $136^{+0.5}_{-0}$ x $66.2^{+0.5}_{-0}$

Title

CUSTOMER DRAWING for
BA678C SAFE AREA INDICATING TEMPERATURE
TRANSMITTER IN PANEL MOUNTING ENCLOSURE

Drawn RH

Checked

Scale NTS

Drawing No. CD678C