



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 0 Certificate history:

Status: Current

Date of Issue: 2010-10-20 Page 1 of 3

Applicant: **GM International S.R.L.**  
Via San Fiorano 70  
20058 Villasanta (MI)  
Italy

Electrical Apparatus: DIN Rail Isolator type D5\*\*\*\*, D5\*\*\*\*-xxx  
Optional accessory:

Type of Protection: Intrinsic safety "i"; Type of Protection "n"; Equipment with equipment protection level (EPL) Ga; Intrinsic safety "ID"

Marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I  
Ex nA nC [ia Ga] IIC T4 Gc, Ex nA nC IIC T4 Gc

Approved for issue on behalf of the IECEx  
Certification Body:

H.-Ch. Simanski

Position:

Head of Certification Body

Signature:  
(for printed version)

Date:

20/10/2010

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**DEKRA EXAM GmbH**  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2010-10-20

Issue No.: 0

Page 2 of 3

Manufacturer: **GM International S.R.L.**  
Via San Fiorano 70  
20058 Villasanta (MI)  
**Italy**

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2007-10</b> Edition: 5	Explosive atmospheres - Part 0: Equipment - General requirements
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2005-03</b> Edition: 3	Electrical apparatus for explosive gas atmospheres Part 15: Construction, test and Marking of Type of Protection "n" electrical apparatus
<b>IEC 60079-26 : 2006</b> Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga
<b>IEC 61241-11 : 2005</b> Edition: 1	Electrical apparatus for use in the presence of combustible dusts - Part 11: Protection by intrinsic safety 'iD'

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

DE/BVS/ExTR10.0103/00

Quality Assessment Report:

NO/DNV/QAR07.0005/03





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2010-10-20

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

Description  
See Annex

Type Code  
See Annex

Ratings  
See Annex

### CONDITIONS OF CERTIFICATION: YES as shown below:

#### 1. Group I application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.

#### 2. Group II application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed:

- outside the hazardous area, or
- shall be mounted inside an enclosure, which is in accordance with IEC 60079-15 in case of alternative installation in areas requiring EPL Gc equipment.

#### 3. Group III application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area.

#### 4. General

The installation of DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be carried out in such a way that the clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure are at least 3 mm, and un-insulated conductors of non-intrinsically safe circuits of other apparatus are situated at least 50 mm from terminals for external intrinsically safe circuits, or are separated from them by an insulating barrier according to clause 6.2.1 of IEC 60079-11:2006.





# IECEx Certificate of Conformity



**Certificate No.:** IECEx BVS 10.0072X  
**Annex**  
**Page 1 of 10**

## Description:

### **Repeater Power Supply type D5011S, D5011S-xxx, D5011D, D5011D-xxx**

Repeater Power Supply type D5011\*, D5011\*-xxx provides a fully floating single or dual channel intrinsically safe DC supply for energizing conventional 2 wires 4 - 20 mA transmitters located in a hazardous area, and repeats the current in floating circuit to drive a safe area load.

### **Repeater Power Supply type D5014S, D5014S-xxx, D5014D, D5014D-xxx**

Repeater Power Supply type D5014\*, D5014\*-xxx provides a fully floating single or dual channel DC supply for energizing conventional 2/3 wires 0/4-20 mA, active or passive, transmitters located in a hazardous area, and repeats the current in floating circuit to drive a safe area load.

Available versions: single channel: type D5014S, D5014S-xxx; dual channel: type D5014D, D5014D-xxx.

### **Powered Isolating Driver type D5020S, D5020S-xxx, D5020D, D5020D-xxx**

Isolating Driver Type D5020\*, D5020\*-xxx provides single or dual channel intrinsically safe power supply for valve positioners or I/P-converters and repeats a non intrinsically safe 4 - 20 mA analogue signal from a controller located in safe area to a load up to 700  $\Omega$ . Available versions: single channel: type D5020S, D5020S-xxx; dual channel: type D5020D, D5020D-xxx.

### **Switch/Proximity Detector Repeater type D5030S, D5030S-xxx, D5030D, D5030D-xxx**

The single and dual channel Switch/Proximity Detector Repeater D5030\*, D5030\*-xxx is a device that can be configured for switch or proximity detector (EN60947-5-6, NAMUR), NO or NC and for NE or ND SPST (D5030D, D5030D-xxx) or SPDT (D5030S, D5030S-xxx) relay output contact.

Each channel enables a safe area load to be controlled by a switch, or a proximity detector, located in a hazardous area.

Available versions of the Switch/Proximity Detector Repeater: single channel: type D5030S, D5030S-xxx. dual channel: type D5030D, D5030D-xxx.

### **Switch/Proximity Detector Repeater type D5031S, D5031S-xxx, D5031D, D5031D-xxx**

The single and dual channel Switch/Proximity Detector Repeater D5031\*, D5031\*-xxx is a device that can be configured for switch or proximity detector (EN60947-5-6, NAMUR), NO or NC and for NO or NC optocoupled open collector transistor output.

Each channel enables a safe area load to be controlled by a switch, or a proximity detector, located in a hazardous area.

Available versions of the Switch/Proximity Detector Repeater: single channel: type D5031S, D5031S-xxx. dual channel: type D5031D, D5031D-xxx.

### **Switch/Proximity Detector Repeater type D5032S, D5032S-xxx, D5032D, D5032D-xxx**

The single and dual channel Switch/Proximity Detector Repeater D5032\*, D5032\*-xxx is a device that can be configured for switch or proximity detector (EN60947-5-6, NAMUR), NO or NC and for NE or ND SPST (D5032D, D5032D-xxx) or SPDT (D5032S, D5032S-xxx) relay output contact.

Each channel enables a safe area load to be controlled by a switch, or a proximity detector, located in a hazardous area.

Available versions of the Switch/Proximity Detector Repeater: single channel: type D5032S, D5032S-xxx. dual channel: type D5032D, D5032D-xxx.

### **Switch/Proximity Interface type D5034S, D5034S-xxx, D5034D, D5034D-xxx**

Switch/Proximity Interface types D5034\*, D5034\*-xxx provide single or dual channel intrinsically safe power supply for switch / proximity switch circuits and repeat the status of contacts or proximity switches in non intrinsically safe output circuits.

Available versions of the Switch/Proximity Interface: single channel: type D5034S, D5034S-xxx. dual channel: type D5034D, D5034D-xxx.





# IECEX Certificate of Conformity



**Certificate No.:** IECEx BVS 10.0072X

**Annex**

**Page 2 of 10**

**Digital Output type D5048S, D5048S-xxx, type D5049S, D5049S-xxx,**

Digital Output Type D504\*S, D504\*S-xxx provides single channel intrinsically safe remote outputs to operate solenoid valves, LEDs or audible alarms driven by non intrinsically safe digital remote signals. The versions type D5048S, D5048S-xxx, type D5049S, D5049S-xxx provide different electrical parameters.

**Relay output type D5090S, D5090S-xxx, D5091S, D5091S-xxx**

**Relay output type D5290S, D5290S-xxx, D5291S, D5291S-xxx**

Relay modules type D5\*9\*S, D5\*9\*S-xxx provides single channel isolation between input and output contacts in different configuration of the contacts with regard to switching of safety related circuits.

The relay modules are designed as EPL Gc equipment, not providing any IS circuits.

**Relay module type D5293S, D5293S-xxx, D5294S, D5294S-xxx**

Relay module type D529\*S, D529\*S-xxx provides single channel isolation between input and output contacts.

D5293S, D5293S-xxx provide 1+1 SPST contact for normally energized load. Three voltage free relay contacts in series are inserted in an external 2-wire supply circuit.

D5294S, D5294S-xxx has 2+2 SPST relay contacts connected in series and then in parallel to avoid spurious trip and to increase availability.

The relay modules are designed as EPL Gc equipment, not providing any IS circuits.

**Short cut explanation**

NO = Normal Open

NC = Normal Closed

NE = Normal Energized

ND = Normal De-energized

SPST = Single-Pole Single-Throw

SPDT = Single-Pole Double-Throw

**Type Code**

Repeater Power Supply	type D5011*, D5011*-xxx
Repeater Power Supply	type D5014*, D5014*-xxx
Powered Isolating Driver	type D5020*, D5020*-xxx
Switch/Proximity Detector Repeater	type D5030*, D5030*-xxx
Switch/Proximity Detector Repeater	type D5031*, D5031*-xxx
Switch/Proximity Detector Repeater	type D5032*, D5032*-xxx
Switch/Proximity Interface	type D5034*, D5034*-xxx
Digital Output	type D5048S, D5048S-xxx, D5049S, D5049S-xxx
Relay Output Module	type D5090S, D5090S-xxx, D5091S, D5091S-xxx
Relay Output Module	type D5290S, D5290S-xxx, D5291S, D5291S-xxx
Relay Output Module	type D5293S, D5293S-xxx, D5294S, D5294S-xxx

In the full designation the "\*" is replaced by letters marking details of construction as follows:

S = single channel

D = dual channel

S-xxx = single channel

D-xxx = dual channel

(Option 'xxx' = non Ex -relevant details of function)





# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X  
Annex  
Page 3 of 10

## Ratings:

1 Non intrinsically safe circuits

1.1 Power supply

DIN Rail Isolator version	Voltage		Power
	U <sub>n</sub>	U <sub>m</sub>	P <sub>n</sub>
	DC [V]	AC [V]	[W]
D5011S, D5011S-xxx	24	250	≤1.35
D5011D, D5011D-xxx	24	250	≤2.90
D5014S, D5014S-xxx,	24	250	≤1.35
D5014D, D5014D-xxx	24	250	≤2.70
D5020S, D5020S-xxx,	24	250	≤1.00
D5020D, D5020D-xxx	24	250	≤2.00
D5030S, D5030S-xxx	24	250	≤0.50
D5030D, D5030D-xxx	24	250	≤1.00
D5031S, D5031S-xxx	24	250	≤0.35
D5031D, D5031D-xxx	24	250	≤0.70
D5032S, D5032S-xxx	24	250	≤0.50
D5032D, D5032D-xxx	24	250	≤1.00
D5034S, D5034S-xxx,	24	250	≤0.40
D5034D, D5034D-xxx	24	250	≤0.80
D5048S, D5048S-xxx	24	250	≤1.80
D5049S, D5049S-xxx	24	250	≤1.80
D5090S, D5090S-xxx, D5091S, D5091S-xxx	24	N / A	≤1.20
D5290S, D5290S-xxx, D5291S, D5291S-xxx	24	N / A	≤2.00
D5293S, D5293S-xxx	24	N / A	≤2.00
D5294S, D5294S-xxx	24	N / A	≤2.70
Remark: N / A = not applicable			



# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X  
Annex  
Page 4 of 10

## 1.2 Input / output signal circuits (General, refers to devices providing IS circuits)

Voltage  $U_m$  = AC 250 V

## 1.3 Relay Output Module D5\*\*\*\* / D5\*\*\*\*-xxx

### 1.3.1 Relay Output Module type D5090S, D5090S-xxx, D5091S, D5091S-xxx

Device marking: Ex nA nC IIC T4 Gc

### 1.3.2 Relay Output Module type D5290S, D5290S-xxx, D5291S, D5291S-xxx

Device marking: Ex nA nC IIC T4 Gc

Single channel; contact rating	Device	D5090*	D5091*	D5290*	D5291*
	Terminals				
contact status when the relay is energized	closed	7-8 ) <sup>1</sup>	7-8 ) <sup>1</sup>	13-14	13-14
	open	9-10 ) <sup>1</sup>	9-10 ) <sup>1</sup>	13-15	13-15
rated AC voltage	250 V			250 V	
rated AC current	4 A			10 A	
rated AC Power	1000 VA			2500 VA	
rated DC voltage	250 V			250 V	
rated DC Current	4 A ) <sup>2</sup>			10 A ) <sup>2</sup>	
rated DC Power	120 W			300 W	
Ambient temperature range	-40 °C ≤ T <sub>a</sub> ≤ +70 °C				
Remark: ) <sup>1</sup> 7+9 common circuit ) <sup>2</sup> Derating curve for DC Voltage					

### 1.3.3 Relay Output Module type D5293S, D5293S-xxx, D5294S, D5294S-xxx

Device marking: Ex nA nC IIC T4 Gc

Single channel; contact rating	Device	D5293*	D5294*
	Terminals		
2-wire load power connection	in	15 (+) -16 (-) ) <sup>1</sup>	15 (+) -16 (-) ) <sup>1</sup>
	out	13 (+) -14 (-) ) <sup>1</sup>	13 (+) -14 (-) ) <sup>1</sup>
rated AC voltage	250 V		250 V
rated AC current	10 A		10 A
rated AC Power	2500 VA		2500 VA
rated DC voltage	250 V		250 V
rated DC Current	10 A ) <sup>2</sup>		10 A ) <sup>2</sup>
rated DC Power	300 W		300 W
Ambient temperature range	-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remark: ) <sup>1</sup> DC as specified, or AC ) <sup>2</sup> Derating curve for DC Voltage			





# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X

Annex

Page 5 of 10

2 Intrinsically safe circuits level of protection Ex ia IIC / IIB / IIA / I

2.1 Repeater Power Supply D5\*\*\*\* / D5\*\*\*\*-xxx

2.1.1 Repeater Power Supply type D5011\*, D5011\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		Terminals		
Channel	1	7-8 ) <sup>1</sup>		
	2	9-10 ) <sup>1</sup>		
Voltage U <sub>o</sub>		DC 25.9 V		
Current I <sub>o</sub>		92 mA		
Power P <sub>o</sub>		594 mW		
Voltage U <sub>i</sub>		N / A		
Current I <sub>i</sub>		N / A		
Power P <sub>i</sub>		N / A		
Effective internal capacitance C <sub>i</sub>		N / A		
Effective internal inductance L <sub>i</sub>		N / A		
Max. external capacitance C <sub>o</sub>	IIC	100 nF		
	IIB iaD	770 nF		
	IIA	2.63 µF		
	I	4.02 µF		
Max. external inductance L <sub>o</sub>	IIC	4.2 mH		
	IIB iaD	16.8 mH		
	IIA	33.7 mH		
	I	55.2 mH		
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	59.9 µH/Ω		
	IIB iaD	239.7 µH/Ω		
	IIA	479.4 µH/Ω		
	I	786.6 µH/Ω		
Characteristics		linear		
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remarks:				
) <sup>1</sup> 2-wire circuit "T*+", "T*-" parameters of supply circuit				
N / A = not applicable				





# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X

Annex

Page 6 of 10

2.1.2 Repeater Power Supply type D5014\*, D5014\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		Terminals			
Channel	1	7-8 ) <sup>1</sup>	7-11 ) <sup>3</sup>	8-11 ) <sup>2</sup>	
	2	9-10 ) <sup>1</sup>	9-12 ) <sup>3</sup>	10-12 ) <sup>2</sup>	
Voltage U <sub>o</sub>		DC 25.9 V		DC +/- 1.1 V	
Current I <sub>o</sub>		92 mA		56 mA	
Power P <sub>o</sub>		594 mW		16 mW	
Voltage U <sub>i</sub>		N / A		DC 30 V	
Current I <sub>i</sub>		N / A		128 mA	
Power P <sub>i</sub>		N / A		N / A	
Effective internal capacitance C <sub>i</sub>		N / A		0 nF	
Effective internal inductance L <sub>i</sub>		N / A		0 mH	
Max. external capacitance C <sub>o</sub>	IIC	100 nF		100 µF	
	IIB iaD	770 nF		1000 µF	
	IIA	2.63 µF		1000 µF	
	I	4.02 µF		1000 µF	
Max. external inductance L <sub>o</sub>	IIC	4.2 mH		11.5 mH	
	IIB iaD	16.8 mH		46.0 mH	
	IIA	33.7 mH		92.1 mH	
	I	55.2 mH		151.1 mH	
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	59.9 µH/Ω		2327.2 µH/Ω	
	IIB iaD	239.7 µH/Ω		9309.0 µH/Ω	
	IIA	479.4 µH/Ω		18618.1 µH/Ω	
	I	786.6 µH/Ω		30545.4 µH/Ω	
Characteristics		linear		linear	
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C			
Remarks:					
) <sup>1</sup> 2-wire circuit "T*+", "T*-" parameters of supply circuit					
) <sup>2</sup> 2-wire circuit "-I*+", "-I*-" parameters of input circuit					
) <sup>3</sup> 3-wire circuit "T*+", "I*+", "I*-" not used					
N / A = not applicable					



# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X  
Annex  
Page 7 of 10

## 2.2 Powered Isolating Driver D5\*\*\*\* / D5\*\*\*\*-xxx

### 2.2.1 Powered Isolating Driver type D5020\*, D5020\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		Terminals	
Channel	1	7-8 ) <sup>1</sup>	
	2	9-10 ) <sup>1</sup>	
Voltage U <sub>o</sub>		DC 25.9 V	
Current I <sub>o</sub>		93 mA	
Power P <sub>o</sub>		595 mW	
Voltage U <sub>i</sub>		N / A	
Current I <sub>i</sub>		N / A	
Power P <sub>i</sub>		N / A	
Effective internal capacitance C <sub>i</sub>		N / A	
Effective internal inductance L <sub>i</sub>		N / A	
Max. external capacitance C <sub>o</sub>	IIC	100 nF	
	IIB iaD	770 nF	
	IIA	2.63 μF	
	I	4.02 μF	
Max. external inductance L <sub>o</sub>	IIC	4.1 mH	
	IIB iaD	16.7 mH	
	IIA	33.5 mH	
	I	54.9 mH	
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	59.7 μH/Ω	
	IIB iaD	239.0 μH/Ω	
	IIA	478.1 μH/Ω	
	I	784.5 μH/Ω	
Characteristics		linear	
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C	
Remarks:			
) <sup>1</sup> 2-wire circuit "O*+", "O*-" parameters of supply circuit			
N / A = not applicable			





# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X  
Annex  
Page 8 of 10

## 2.3 Switch/Proximity Detector Repeater / Switch/Proximity Interface D5\*\*\*\* / D5\*\*\*\*-xxx

### 2.3.1 Switch/Proximity Detector Repeater type D5030\*, D5030\*-xxx

Device marking: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

### 2.3.2 Switch/Proximity Detector Repeater type D5031\*, D5031\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

### 2.3.3 Switch/Proximity Detector Repeater type D5032\*, D5032\*-xxx

Device marking: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters	Device	D5030*	D5031*	D5032*
	Terminals			
Channel	1	7-8 ) <sup>1</sup>	7-8 ) <sup>1</sup>	7-8 )1
	2	9-10 ) <sup>1</sup>	9-10 ) <sup>1</sup>	9-10 )1
Voltage U <sub>o</sub>		DC10.5 V	DC10.5 V	DC10.5 V
Current I <sub>o</sub>		22 mA	22 mA	22 mA
Power P <sub>o</sub>		56 mW	56 mW	56 mW
Voltage U <sub>i</sub>		N / A	N / A	N / A
Current I <sub>i</sub>		N / A	N / A	N / A
Power P <sub>i</sub>		N / A	N / A	N / A
Effective internal capacitance C <sub>i</sub>		1.1 nF	1.1 nF	1.1 nF
Effective internal inductance L <sub>i</sub>		N / A	N / A	N / A
Max. external capacitance C <sub>o</sub>	IIC	2.41 µF	2.41 µF	2.41 µF
	IIB iaD	16.8 nF	16.8 nF	16.8 nF
	IIA	75 µF	75 µF	75 µF
	I	66 µF	66 µF	66 µF
Max. external inductance L <sub>o</sub>	IIC	78.3 mH	78.3 mH	78.3 mH
	IIB iaD	313.4 mH	313.4 mH	313.4 mH
	IIA	626.9 mH	626.9 mH	626.9 mH
	I	1028.6 mH	1028.6 mH	1028.6 mH
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	635.9 µH/Ω	635.9 µH/Ω	635.9 µH/Ω
	IIB iaD	2543.9 µH/Ω	2543.9µH/Ω	2543.9 µH/Ω
	IIA	5087.9 µH/Ω	5087.9µH/Ω	5087.9 µH/Ω
	I	8347.4 µH/Ω	8347.4µH/Ω	8347.4 µH/Ω
Characteristics		linear	linear	linear
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remarks:				
) <sup>1</sup> 2-wire circuit "I*+", "I*-" parameters of supply circuit				
N / A = not applicable				



# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X

Annex

Page 9 of 10

## 2.3.4 Switch/Proximity Interface type D5034\*, D5034\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		Terminals		
Channel	1	7-8 ) <sup>1</sup>		
	2	9-10 ) <sup>1</sup>		
Voltage U <sub>o</sub>		DC10.5 V		
Current I <sub>o</sub>		15 mA		
Power P <sub>o</sub>		39 mW		
Voltage U <sub>i</sub>		N / A		
Current I <sub>i</sub>		N / A		
Power P <sub>i</sub>		N / A		
Effective internal capacitance C <sub>i</sub>		N / A		
Effective internal inductance L <sub>i</sub>		N / A		
Max. external capacitance C <sub>o</sub>	IIC	2.41 μF		
	IIB iaD	16.8 nF		
	IIA	75 μF		
	I	66 μF		
Max. external inductance L <sub>o</sub>	IIC	163.2 mH		
	IIB iaD	652.8 mH		
	IIA	1305.6 mH		
	I	2142.0 mH		
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	918.2 μH/Ω		
	IIB iaD	3672.9 μH/Ω		
	IIA	7345.8 μH/Ω		
	I	12051.8 μH/Ω		
Characteristics		linear		
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remarks:				
) <sup>1</sup> 2-wire circuit "T*+", "T*-" parameters of supply circuit				
N / A = not applicable				





# IECEx Certificate of Conformity



Certificate No.: IECEx BVS 10.0072X

Annex

Page 10 of 10

## 2.4 Digital Output Driver D5\*\*\*\* / D5\*\*\*\*-xxx

### 2.4.1 Digital Output Driver type D5048S, D5048S-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

### 2.4.2 Digital Output Driver type D5049S, D5049S-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		Terminals		
Channel	1	7-10 ) <sup>1</sup>	8-10 ) <sup>2</sup>	9-10 ) <sup>3</sup>
	2	N / A	N / A	N / A
Voltage U <sub>o</sub>		DC 24.8 V	DC 24.8 V	DC 24.8 V
Current I <sub>o</sub>		147 mA	108 mA	93 mA
Power P <sub>o</sub>		907 mW	667 mW	571 mW
Voltage U <sub>i</sub>		N / A	N / A	N / A
Current I <sub>i</sub>		N / A	N / A	N / A
Power P <sub>i</sub>		N / A	N / A	N / A
Effective internal capacitance C <sub>i</sub>		N / A	N / A	N / A
Effective internal inductance L <sub>i</sub>		N / A	N / A	N / A
Max. external capacitance C <sub>o</sub>	IIC	113 nF	113 nF	113 nF
	IIB iaD	860 nF	860 nF	860 nF
	IIA	3.05 µF	3.05 µF	3.05 µF
	I	4.35 µF	4.35 µF	4.35 µF
Max. external inductance L <sub>o</sub>	IIC	1.65 mH	3.07 mH	4.19 mH
	IIB iaD	6.63 mH	12.30 mH	16.79 mH
	IIA	13.27 mH	24.60 mH	33.58 mH
	I	21.78 mH	40.36 mH	55.09 mH
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	39.2 µH/Ω	53.3 µH/Ω	62.3 µH/Ω
	IIB iaD	156.8 µH/Ω	213.5 µH/Ω	249.4 µH/Ω
	IIA	313.6 µH/Ω	427.0 µH/Ω	498.9 µH/Ω
	I	514.6 µH/Ω	700.6 µH/Ω	818.5 µH/Ω
Characteristics		linear	linear	linear
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remarks:				
) <sup>1</sup> 2-wire circuit 'Out A' "O1+", "O-" parameters of supply circuit				
) <sup>2</sup> 2-wire circuit 'Out B' "O2+", "O-" parameters of supply circuit				
) <sup>3</sup> 2-wire circuit 'Out C' "O3+", "O-" parameters of supply circuit				
"O-" = common ground for "O*+"				
'Out A / B / C' are used exclusive or only				
N / A = not applicable				



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 1

Status: Current

Date of Issue: 2013-10-28

Page 1 of 4

Certificate history:

Issue No. 1 (2013-10-28)

Issue No. 0 (2010-10-20)

Applicant: **GM International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

Electrical Apparatus: DIN Rail Isolator type D5\*\*\*\*, D5\*\*\*\*-xxx  
Optional accessory:

Type of Protection: Equipment protection by intrinsic safety "i", Equipment protection by intrinsic safety "i", Equipment protection by type of protection "n", Equipment with equipment protection level (EPL) Ga

Marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I  
Ex nA nC [ia Ga] IIC T4 Gc, Ex nA nC IIC T4 Gc

Approved for issue on behalf of the IECEx  
Certification Body:

H.-Ch. Simanski

Position:

Head of Certification Body

Signature:  
(for printed version)

Date:

28.10.2013

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

DEKRA EXAM GmbH  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2013-10-28

Issue No.: 1

Page 2 of 4

Manufacturer: **GM International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2010</b> Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
<b>IEC 60079-26 : 2006</b> Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:  
[DE/BVS/ExTR10.0103/01](#)

Quality Assessment Report:  
[NO/DNV/QAR07.0005/04](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2013-10-28

Issue No.: 1

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### Type Code

(no extension)

#### Description:

DIN Rail Isolators have been subjected optionally to some minor changes not affecting IS parameters.

#### Ratings:

Parameters specified in previous issue 00 remain valid without change.

Lo, Co and Lo/Ro parameters specified for Group IIB in previous issue 00 apply in addition for Group IIIC.

### CONDITIONS OF CERTIFICATION: YES as shown below:

#### 1. Group I application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.

#### 2. Group II application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed:

- outside the hazardous area, or
- shall be mounted inside an enclosure, which is in accordance with IEC 60079-15 in case of alternative installation in areas requiring EPL Gc equipment.

#### 3. Group III application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.

#### 4. General

The installation of DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be carried out in such a way that the clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure are at least 3 mm, and un-insulated conductors of non-intrinsically safe circuits of other apparatus are situated at least 50 mm from terminals for external intrinsically safe circuits, or are separated from them by an insulating barrier according to clause 6.2.1 of IEC 60079-11:2011.





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2013-10-28

Issue No.: 1

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

DIN Rail Isolators have been subjected to some minor changes not affecting IS parameters.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.:2

Status: **Current**

Date of Issue: 2014-04-11

Page 1 of 4

Certificate history:

Issue No. 2 (2014-4-11)  
Issue No. 1 (2013-10-28)  
Issue No. 0 (2010-10-20)

Applicant: **GM International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

Electrical Apparatus: **DIN Rail Isolator type D5\*\*\*\*, D5\*\*\*\*-xxx**  
Optional accessory:

Type of Protection: **Equipment protection by type of protection "n"**

Marking: Ex nA nC IIC T4 Gc

Approved for issue on behalf of the IECEx  
Certification Body:

H.-Ch. Simanski

Position:

Head of Certification Body

Signature:  
(for printed version)

  
11.4.2014

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**DEKRA EXAM GmbH**  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2014-04-11

Issue No.: 2

Page 2 of 4

Manufacturer: **GM International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
**Italy**

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

### Test Report:

DE/BVS/ExTR10.0103/02

### Quality Assessment Report:

NO/DNV/QAR07.0005/05



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2014-04-11

Issue No.: 2

Page 3 of 4

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

#### Type Code

Relay Output Module type D5290S-078 and D5290S-078-xxx  
(Option 'xxx' = non Ex -relevant details of function)

#### Description

The Relay Modules type series D5\*9\*S, D5\*9\*S-xxx, providing single channel isolation between supply-input and output contacts have been extended with new models D5290S-078 and D5290S-078-xxx.

The Relay Output Modules type D5290S-078 and D5290S-078-xxx is designed as EPL Gc equipment, not providing any IS circuits.

Electronic components of the Relay Output Module are arranged on printed-circuit-boards (PCB) packaged in plastic enclosures suitable for installation on T35 DIN Rails.

#### 1 Power supply circuit

	Voltage	Power Dissipation
Relay Output Module type	$U_n$	$P_n$
	DC [V]	[W]
D5290S-078, D5290S-078-xxx	24	$\leq 1.5$

#### 2 Relay contacts

Contact Rating			
Voltage $U_n$	AC 250 V	DC 250 V	DC 30 V
Current $I_{load}$ ) <sup>1</sup>	$\leq 5$ A	$\leq 0,2$ A ) <sup>2</sup>	$\leq 5$ A
Power ) <sup>1</sup>	$\leq 1250$ VA	) <sup>2</sup>	$\leq 175$ W
) <sup>1</sup> resistive load ) <sup>2</sup> see detailed data sheet			

#### 3 Ambient temperature range $-40^\circ\text{C} \leq T_a \leq +70^\circ\text{C}$

### CONDITIONS OF CERTIFICATION: YES as shown below:

The Relay Output Module type D5290S-078 / type D5290S-078-xxx shall be installed inside an enclosure, which is in accordance with IEC 60079-15.





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2014-04-11

Issue No.: 2

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

The Relay Modules type series D5\*9\*S, D5\*9\*S-xxx, providing single channel isolation between supply-input and output contacts have been extended with new models D5290S-078 and D5290S-078-xxx.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 3

Status: **Current**

Date of Issue: **2015-02-04** Page 1 of 5

Applicant: **G.M. International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

**Certificate history:**

Issue No. 3 (2015-2-4)  
Issue No. 2 (2014-4-11)  
Issue No. 1 (2013-10-28)  
Issue No. 0 (2010-10-20)

Electrical Apparatus: **DIN Rail Isolator (extension: Relay Output Module) type D5\*\*\*\*, D5\*\*\*\*-xxx (extension: D529\*S / D529\*S-xxx; \*\* = 3, 4, 5)**  
Optional accessory:

Type of Protection: **Equipment protection by type of protection "n"**

Marking: **Ex nA nC IIC T4 Gc**

Approved for issue on behalf of the IECEx  
Certification Body:

H.-Ch. Simanski

Position:

Head of Certification Body

Signature:  
(for printed version)

Date:

9.2.2015

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**DEKRA EXAM GmbH**  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-02-04

Issue No.: 3

Page 2 of 5

Manufacturer: **G.M. International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

### Test Report:

DE/BVS/ExTR10.0103/03

### Quality Assessment Report:

NO/DNV/QAR07.0005/05



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-02-04

Issue No.: 3

Page 3 of 5

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### Type Code

Relay Output Module: type D5293S / type D5293S-xxx, type D5294S / type D5294S-xxx  
type D5295S / type D5295S-xxx  
(Option 'xxx' = non Ex-relevant details of construction or function)

#### Description

The Relay Output-Modules type D5293S / type D5293S-xxx, type D5294S / type D5294S-xxx may be subjected to minor change optionally and enhanced with models Relay Output-Module type D5295S / type D5295S-xxx.  
The Relay Output Module type D5295S / type D5295S-xxx is designed as EPL Gc equipment, not providing any IS circuits.  
Electronic components of the Relay Output-Module type D5295S / type D5295S-xxx are arranged on printed-circuit-boards (PCB) packaged in plastic enclosures suitable for installation on T35 DIN Rails.

### CONDITIONS OF CERTIFICATION: YES as shown below:

The Relay Output Module type type D5293S / type D5293S-xxx, type D5294S / type D5294S-xxx type D5295S / type D5295S-xxx shall be installed inside an enclosure, which is in accordance with IEC 60079-15.





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-02-04

Issue No.: 3

Page 4 of 5

## EQUIPMENT(continued):

### Rating

#### 1 Power supply circuit

Relay Output Module type	Voltage	Power dissipation
	$U_n$	$P_n$
	DC [V]	[W]
D5293S, D5293S-xxx	24	$\leq 1.2$
D5294S, D5294S-xxx D5295S, D5295S-xxx	24	$\leq 1.45$

#### 2 Relay contacts

Contact rating			
Voltage $U_n$	AC 250 V	DC 250 V	DC 30 V
Current $I_{load}^{1)}$	$\leq 4$ A	$\leq 0.2$ A <sup>2)</sup>	$\leq 4$ A
Power <sup>1)</sup>	$\leq 1000$ VA	<sup>2)</sup>	$\leq 120$ W
<sup>1)</sup> resistive load	<sup>2)</sup> see detailed data sheet		

#### 3 Ambient temperature range $-40\text{ }^{\circ}\text{C} \leq T_a \leq +70\text{ }^{\circ}\text{C}$



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-02-04

Issue No.: 3

Page 5 of 5

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Models subjected to change: type D5293S / D5293S-xxx, type D5294S / D5294S-xxx  
Extension with new models: type D5295S / D5295S-xxx  
(Option 'xxx' = non Ex-relevant details of construction or function)





# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 4

Status: Current

Date of Issue: 2015-07-16 Page 1 of 4

Applicant: G.M. International S.R.L.  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

### Certificate history:

Issue No. 4 (2015-7-16)  
Issue No. 3 (2015-2-4)  
Issue No. 2 (2014-4-11)  
Issue No. 1 (2013-10-28)  
Issue No. 0 (2010-10-20)

Electrical Apparatus: Switch Repeater type D5093S, D5093S-xxx, D5093D and D5093D-xxx  
Optional accessory:

Type of Protection: Equipment protection by type of protection "n"

Marking: Ex nA IIC T4 Gc

Approved for issue on behalf of the IECEx  
Certification Body:

H.-Ch. Simanski

Position: Head of Certification Body

Signature:  
(for printed version)



16.7.2015

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

DEKRA EXAM GmbH  
Dinnendahlstrasse 9  
44809 Bochum  
Germany



DEKRA  
DEKRA EXAM GmbH



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-07-16

Issue No.: 4

Page 2 of 4

Manufacturer: **G.M. International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

##### Test Report:

[DE/BVS/ExTR10.0103/04](#)

##### Quality Assessment Report:

[NO/DNV/QAR07.0005/05](#)





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-07-16

Issue No.: 4

Page 3 of 4

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

#### Type Code

Switch Repeater type: D5093S, D5093S-xxx, D5093D and D5093D-xxx.  
(Option 'xxx' = non Ex-relevant details of construction or function)

#### Description

The Switch Repeater type: D5093S, D5093S-xxx, D5093D or D5093D-xxx is designed as EPL Gc equipment, not providing any IS circuits and intended for installation inside enclosures, complying with IEC 60079-15. Electronic components of the Switch Repeater are arranged on a printed-circuit-board (PCB) packaged in a plastic enclosure suitable for installation on T35 DIN Rails.

#### Rating

Switch Repeater type: D5093S, D5093S-xxx, D5093D and D5093D-xxx

#### Power supply circuit

Switch Repeater module type	Voltage	Power Dissipation
	$U_n$	$P_n$
	DC/AC [V]	[W]
D5093S, D5093S-xxx	18...250	$\leq 0.75$
D5093D, D5093D-xxx	18...250	$\leq 1.5$

Switch Output:  $U_n$  DC 35 V;  $I_n$  50 mA

Ambient temperature range  $-40\text{ }^{\circ}\text{C} \leq T_a \leq +70\text{ }^{\circ}\text{C}$

#### CONDITIONS OF CERTIFICATION: YES as shown below:

The Switch Repeater type: D5093S, D5093S-xxx, D5093D and D5093D-xxx shall be installed inside an enclosure, which is in accordance with IEC 60079-15.

Conditions of Use dealing with previous models, subject to issue 00, issue 01, issue 02, issue 03 remain valid without change.



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-07-16

Issue No.: 4

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Examination of the Switch Repeater type D5093S, D5093S-xxx, D5093D and D5093D-xxx in accordance with the standards listed above.

Previous issues of the CoC and subjects thereto remain valid without change.






# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	IECEx BVS 10.0072X	issue No.:	5	Certificate history:
Status:	Current			Issue No. 5 (2015-12-14)
Date of Issue:	2015-12-14	Page 1 of 5		Issue No. 4 (2015-7-16)
Applicant:	G.M. International S.R.L. Via Mameli, 53-55 20852 Villasanta (MB) Italy			Issue No. 3 (2015-2-4)
				Issue No. 2 (2014-4-11)
				Issue No. 1 (2013-10-28)
				Issue No. 0 (2010-10-20)
Electrical Apparatus:	DIN Rail Isolator (extention: Relay Output, Switch/Proximity Detector repeaters) type D5****, D5****-xxx (extention: D5090S-086, D5036*-*/ D5037*-*)			
Optional accessory:				
Type of Protection:	Equipment protection by type of protection "n"			
Marking:	Ex nA nC [ia Ga] IIC T4 Gc; [Ex ia Da] IIC; [Ex ia Ma] I Ex nA [ia Ga] IIC T4 Gc; Ex nA nC IIC T4 Gc			
Approved for issue on behalf of the IECEx Certification Body:	H.-Ch. Simanski			
Position:	Head of Certification Body			
Signature: (for printed version)				
Date:	14.12.2015			

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

DEKRA EXAM GmbH  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-12-14

Issue No.: 5

Page 2 of 5

Manufacturer: **G.M. International S.R.L.**  
Via Mameli, 53-55  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2010</b> Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:  
[DE/BVS/ExTR10.0103/05](#)

Quality Assessment Report:  
[NO/DNV/QAR07.0005/06](#)





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-12-14

Issue No.: 5

Page 3 of 5

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### General product information:

DIN Rail Isolators of D5\*\*\* / D5\*\*\*\*-xxx type series have been extended with a new relay output and new Switch/Proximity Detector Repeaters.

#### Type Code

Relay output: type D5090S-086  
Switch/Proximity Detector Repeater: type D5036\* / type D5036\*-xxx,  
type D5037\* / type D5037\*-xxx

In the full designation the "\*\*\*" is replaced by letters marking details of construction as follows:

S = single channel S-xxx = single channel

D = dual channel D-xxx = dual channel

(Option 'xxx' = non Ex-relevant details of construction or function)

#### CONDITIONS OF CERTIFICATION: YES as shown below:

1. Group I application:  
DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.
2. Group II application:  
DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed:  
- outside the hazardous area, or  
- shall be mounted inside an enclosure, which is in accordance with IEC 60079-15 in case of alternative installation in areas requiring EPL Gc equipment.
3. Group III application:  
DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.
4. General  
The installation of DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be carried out in such a way that the clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure are at least 3 mm, and un-insulated conductors of non-intrinsically safe circuits of other apparatus are situated at least 50 mm from terminals for external intrinsically safe circuits, or are separated from them by an insulating barrier according to clause 6.2.1 of IEC 60079-11:2011.



# IECEx Certificate of Conformity

Certificate No.:

IECEx BVS 10.0072X

Date of Issue:

2015-12-14

Issue No.: 5

Page 4 of 5

## EQUIPMENT(continued):

### Description

#### Relay Output type D5090S-086

The Relay Output type D5090S-086 provides single channel isolation between remote input and output contact; configuration three contacts in series.

Electronic components of the new relay output model are arranged on a printed-circuit-board (PCB) packaged in a plastic enclosure suitable for installation on T35 DIN Rails (or on termination board).

The relay output is designed as EPL Gc equipment, not providing any IS circuits.

#### Switch/Proximity Detector Repeater type D5036S, D5036S-xxx, D5036D, D5036D-xxx

The single and dual channel Switch/Proximity Detector Repeater D5036\*, D5036\*-xxx generates fully floating intrinsically safe power supply for proximity sensor field devices or for voltage free contacts of field devices and repeats the operation status of the proximity sensors / voltage free contacts on the non-intrinsically safe side by means of voltage free relay contacts.

Each channel enables a safe area load to be controlled by a switch, or a proximity detector, located in a hazardous area.

The Switch/Proximity Detector Repeater D5036\*, D5036\*-xxx is designed for installation on T35 DIN Rail only.

#### Switch/Proximity Detector Repeater type D5037S, D5037S-xxx, D5037D, D5037D-xxx

The single and dual channel Switch/Proximity Detector Repeater D5037\*, D5037\*-xxx generates fully floating intrinsically safe power supply for proximity sensor field devices or for voltage free contacts of field devices and repeats the operation status of the proximity sensors / voltage free contacts on the non-intrinsically safe side by means of voltage free opto-isolator outputs.

Each channel enables a safe area load to be controlled by a switch, or a proximity detector, located in a hazardous area.

The Switch/Proximity Detector Repeater D5037\*, D5037\*-xxx is designed for installation on T35 DIN Rail or on Termination Board.

Electronic components of the new Switch/Proximity Detector Repeater models are arranged on a printed-circuit-board (PCB) packaged in a plastic enclosure suitable for installation on T35 DIN Rails (or on termination board).

Switch/Proximity Detector Repeaters of D5036\*-\*/D5037\*-\* type series provide safe galvanic separation between intrinsically safe circuits and non-intrinsically safe signal circuits / non-intrinsically safe power supply on the PCB up to a sum of peak values of rated voltages of 375 V.

### Listing of all components used, referring to older standards:

N / A

### Rating:

See Annex





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2015-12-14

Issue No.: 5

Page 5 of 5

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See Annex



# IECEx Certificate of Conformity



**Certificate No.:** IECEx BVS 10.0072X **issue No.:** 5  
**Annex**  
**Page 1 of 3**

## Details of change

Refers to the following previous models, subject to issue 00 / issue 01 of the Test Report and extension with new models:

- Switch/Proximity Detector Repeater type D5030\*, D5030\*-xxx, D5031\*, D5031\*-xxx, D5032\*, D5032\*-xxx  
Switch/Proximity Interface type D5034\*, D5034\*-xxx:  
Correction of printing mistake  $C_o$  parameter 16.8 nF to 16.8  $\mu$ F referring to Group IIB and IIIC
- Relay Output type D5090S, D5090S-xxx, D5091S, D5091S-xxx  
Extension of rated AC and DC current from 4 A to 5 A
- Relay Output type D5293S, D5293S-xxx,  
type D5294S, D5294S-xxx, D5295S, D5295S-xxx  
type D5093S, D5093S-xxx, D5093D, D5093D-xxx

Optional revision / omitting of components in the non-IS circuitry

- extension of Relay Output Modules with new version type D5090S-086.
- extension of Switch/Proximity Detector Repeaters with new models type D5036\*, D5036\*-xxx,  
type D5037\*, D5037\*-xxx.

Previous issues 00 to 04 of the CoC, dealing with DIN Rail Isolators of D5\*\*\* / D5\*\*\*\*-xxx type series not listed as subject to 'Details of change' remain valid without change.

## Rating:

- 1 Non intrinsically safe circuits
- 1.1 Power supply

Device	Voltage		Power
	$U_n$	$U_m$	$P_n$
	DC [V]	AC [V]	[W]
D5090S-086	24	N / A	$\leq 1.2$
D5036S, D5036S-xxx	24	250	$\leq 0.5$
D5036D, D5036D-xxx	24	250	$\leq 1$
D5037S, D5037S-xxx	24	250	$\leq 0.35$
D5037D, D5037D-xxx	24	250	$\leq 0.7$
Remark: N / A = not applicable			

- 1.2 Input / output signal circuits (General, refers to devices providing IS circuits)  
Voltage  $U_m$  = AC 250 V

**Certificate No.:** IECEx BVS 10.0072X issue No.: 5

**Annex**

**Page 2 of 3**

## 1.3 Relay Contacts of Relay Outputs

Single channel; contact rating	Device	D5090S D5090S-086 D5091S	D5290S D5291S
	Terminals		
contact status when the relay is energized	closed	7-8 <sup>1)</sup>	13-14
	open	9-10 <sup>1)</sup>	13-15
rated AC voltage		250 V	250 V
rated AC current		5 A	10 A
rated AC Power		1250 VA	2500 VA
rated DC voltage		250 V	250 V
rated DC Current		5 A <sup>2)</sup>	10 A <sup>2)</sup>
rated DC Power		140 W	300 W
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C	
Remark:			
<sup>1)</sup> 7+9 common circuit			
<sup>2)</sup> Derating curve for DC Voltage			

## 2 Intrinsically safe circuits level of protection Ex ia IIC / IIB / IIA / I

### 2.1 Switch/Proximity Detector Repeater / Switch/Proximity Interface D503\*\* / D503\*\*-xxx

#### 2.1.1 Switch/Proximity Detector Repeater type D5030\*, D5030\*-xxx

Device marking: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

#### 2.1.2 Switch/Proximity Detector Repeater type D5031\*, D5031\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

#### 2.1.3 Switch/Proximity Detector Repeater type D5032\*, D5032\*-xxx

Device marking: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters	Device	D5030*	D5031*	D5032*
Terminals				
Channel	1	7-8 <sup>1)</sup>	7-8 <sup>1)</sup>	7-8 <sup>1)</sup>
	2	9-10 <sup>1)</sup>	9-10 <sup>1)</sup>	9-10 <sup>1)</sup>
Voltage $U_o$		DC10.5 V	DC10.5 V	DC10.5 V
Current $I_o$		22 mA	22 mA	22 mA
Power $P_o$		56 mW	56 mW	56 mW
Voltage $U_i$		N / A	N / A	N / A
Current $I_i$		N / A	N / A	N / A
Power $P_i$		N / A	N / A	N / A
Effective internal capacitance $C_i$		1.1 nF	1.1 nF	1.1 nF
Effective internal inductance $L_i$		N / A	N / A	N / A
Max. external capacitance $C_o$	IIC	2.41 $\mu\text{F}$	2.41 $\mu\text{F}$	2.41 $\mu\text{F}$
	IIB, IIIC	16.8 $\mu\text{F}$	16.8 $\mu\text{F}$	16.8 $\mu\text{F}$
	IIA	75 $\mu\text{F}$	75 $\mu\text{F}$	75 $\mu\text{F}$
	I	66 $\mu\text{F}$	66 $\mu\text{F}$	66 $\mu\text{F}$
Max. external inductance $L_o$	IIC	78.3 mH	78.3 mH	78.3 mH
	IIB, IIIC	313.4 mH	313.4 mH	313.4 mH
	IIA	626.9 mH	626.9 mH	626.9 mH
	I	1028.6 mH	1028.6 mH	1028.6 mH
Max. inductance / resistance ratio $L_o/R_o$	IIC	635.9 $\mu\text{H}/\Omega$	635.9 $\mu\text{H}/\Omega$	635.9 $\mu\text{H}/\Omega$
	IIB, IIIC	2543.9 $\mu\text{H}/\Omega$	2543.9 $\mu\text{H}/\Omega$	2543.9 $\mu\text{H}/\Omega$
	IIA	5087.9 $\mu\text{H}/\Omega$	5087.9 $\mu\text{H}/\Omega$	5087.9 $\mu\text{H}/\Omega$
	I	8347.4 $\mu\text{H}/\Omega$	8347.4 $\mu\text{H}/\Omega$	8347.4 $\mu\text{H}/\Omega$
Characteristics		linear	linear	linear
Ambient temperature range		$-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$		





# IECEx Certificate of Conformity



**Certificate No.:** IECEx BVS 10.0072X issue No.: 5

**Annex**

**Page 3 of 3**

Remarks:

<sup>1)</sup> 2-wire circuit "I\*+", "I\*-" parameters of supply circuit

N / A = not applicable

2.1.4 Switch/Proximity Interface type D5034\*, D5034\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

2.1.5 Switch/Proximity Detector Repeater type D5036\*, D5036\*-xxx

Device marking: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

2.1.6 Switch/Proximity Detector Repeater type D5037\*, D5037\*-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters	Device	D5034*	D5036*	D5037*
	Terminals			
Channel	1	7-8 <sup>1)</sup>	7-8 <sup>1)</sup>	7-8 <sup>1)</sup>
	2	9-10 <sup>1)</sup>	9-10 <sup>1)</sup>	9-10 <sup>1)</sup>
Voltage U <sub>o</sub>		DC10.5 V	DC10.5 V	DC10.5 V
Current I <sub>o</sub>		15 mA	22 mA	22 mA
Power P <sub>o</sub>		39 mW	56 mW	56 mW
Voltage U <sub>i</sub>		N / A	N / A	N / A
Current I <sub>i</sub>		N / A	N / A	N / A
Power P <sub>i</sub>		N / A	N / A	N / A
Effective internal capacitance C <sub>i</sub>		N / A	1.1 nF	1.1 nF
Effective internal inductance L <sub>i</sub>		N / A	N / A	N / A
Max. external capacitance C <sub>o</sub>	IIC	2.41 μF	2.41 μF	2.41 μF
	IIB, IIIC	16.8 μF	16.8 μF	16.8 μF
	IIA	75 μF	75 μF	75 μF
	I	66 μF	66 μF	66 μF
Max. external inductance L <sub>o</sub>	IIC	163.2 mH	78.3 mH	78.3 mH
	IIB, IIIC	652.8 mH	313.4 mH	313.4 mH
	IIA	1305.6 mH	626.9 mH	626.9 mH
	I	2142.0 mH	1028.6 mH	1028.6 mH
Max. inductance / resistance ratio L <sub>o</sub> /R <sub>o</sub>	IIC	918.2 μH/Ω	635.9 μH/Ω	635.9 μH/Ω
	IIB, IIIC	3672.9 μH/Ω	2543.9 μH/Ω	2543.9 μH/Ω
	IIA	7345.8 μH/Ω	5087.9 μH/Ω	5087.9 μH/Ω
	I	12051.8 μH/Ω	8347.4 μH/Ω	8347.4 μH/Ω
Characteristics		linear	linear	linear
Ambient temperature range		-40 °C ≤ T <sub>a</sub> ≤ +70 °C		
Remarks:				
<sup>1)</sup> 2-wire circuit "I*+", "I*-" parameters of supply circuit				
N / A = not applicable				



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 6

Status: Current

Date of Issue: 2016-09-22 Page 1 of 4

Applicant: **G.M. International S.R.L.**  
Via G. Mameli 53/55  
20852 Villasanta (MB)  
Italy

Certificate history:  
Issue No. 6 (2016-9-22)  
Issue No. 5 (2015-12-14)  
Issue No. 4 (2015-7-16)  
Issue No. 3 (2015-2-4)  
Issue No. 2 (2014-4-11)  
Issue No. 1 (2013-10-28)  
Issue No. 0 (2010-10-20)

Equipment: Relay Output (extension of DIN Rail Isolator type series) type D5094S, D5094S-xxx, D5095S or D5095S-xxx, D5096S, D5096S-xxx, D5097S or D5097S-xxx  
Optional accessory:

Type of Protection: Equipment protection by type of protection "n"


Marking: Ex nA nC IIC T4 Gc

Approved for issue on behalf of the IECEx Certification Body: J. Koch

Position: Head of Certification Body

Signature:  
(for printed version)

Date:

  
22.9.16

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

DEKRA EXAM GmbH  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
On the safe side.



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2016-09-22

Issue No.: 6

Page 2 of 4

Manufacturer: **G.M. International S.R.L.**  
Via G. Mameli 53/55  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

#### Test Report:

DE/BVS/ExTR10.0103/06

#### Quality Assessment Report:

NO/DNV/QAR07.0005/06





# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2016-09-22

Issue No.: 6

Page 3 of 4

## Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

#### Type Code

Relay Output type: D5094S, D5094S-xxx, D5095S or D5095S-xxx,  
Relay Output with Diagnostic type: D5096S, D5096S-xxx, D5097S or D5097S-xxx.  
(Option 'xxx' = non Ex-relevant details of construction or function)

#### Description

The Relay Outputs (without / with diagnostic) type D5094S, D5094S-xxx, D5095S, D5095S-xxx, D5096S, D5096S-xxx, D5097S, D5097S-xxx are designed as EPL Gc equipment, which does not provide any intrinsically safe circuits and are intended for installation inside enclosures, complying with IEC 60079-15.

Electronic components of the Relay Outputs are arranged on a printed-circuit-board (PCB) packaged in a plastic enclosure suitable for installation on T35 DIN Rails or alternatively on Termination Boards.

Listing of all components used referring to older standards: not applicable.

#### Rating

Relay Output type	Voltage	Power dissipation
	$U_n$	$P_n$
	DC [V]	[W]
D5094S, D5094S-xxx	24 (21.6...27.6)	1.4
D5095S, D5095S-xxx		1.4
D5096S, D5096S-xxx		$\leq 1.4 + 0.37$
D5097S, D5097S-xxx		$\leq 1.4 + 0.37$

Relay contact circuit  $U_n$  AC 250 V;  $I_n$  5 A,  $P_n$  1250 VA

$U_n$  DC 250 V;  $I_n$  5 A,  $P_n$  140 W

Fault signal output  $U_n$  DC 35 V;  $I_n$  100 mA (D5096S, D5096S-xxx, D5097S, D5097S-xxx only)

Ambient temperature range:  $-40\text{ }^{\circ}\text{C} \leq T_a \leq +70\text{ }^{\circ}\text{C}$

#### CONDITIONS OF CERTIFICATION: YES as shown below:

The Relay Outputs type D5094S, D5094S-xxx, D5095S, D5095S-xxx, D5096S, D5096S-xxx, D5097S, D5097S-xxx shall be installed inside an enclosure, which is in accordance with IEC 60079-15. Conditions of Use dealing with previous models, subject to issue 00 to issue 05 remain valid without change.



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2016-09-22

Issue No.: 6

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

The DIN Rail Isolator type series D5\*\*\*\* / D5\*\*\*\*-xxx is extended with new models: Relay Outputs type D5094S, D5094S-xxx, D5095S, D5095S-xxx, D5096S, D5096S-xxx, D5097S, D5097S-xxx.  
Previous issues of the Test Report and subjects thereto remain valid without change.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 10.0072X issue No.: 7

Status: **Current**

Date of Issue: 2017-06-06 Page 1 of 4

Applicant: **G.M. International S.R.L.**  
Via G. Mameli 53/55  
20852 Villasanta (MB)  
Italy

### Certificate history:

Issue No. 7 (2017-6-6)  
Issue No. 6 (2016-9-22)  
Issue No. 5 (2015-12-14)  
Issue No. 4 (2015-7-16)  
Issue No. 3 (2015-2-4)  
Issue No. 2 (2014-4-11)  
Issue No. 1 (2013-10-28)  
Issue No. 0 (2010-10-20)

Equipment: **Relay Output type D5293S(-xxx), D5294S(-xxx), D5295S(-xxx)**  
Optional accessory:

Type of Protection: **Equipment protection by type of protection "n"**


Marking: **Ex nA nC IIC T4 Gc**

Approved for issue on behalf of the IECEx Certification Body: **Jörg Koch**

Position: **Head of Certification Body**

Signature:  
(for printed version)

Date:

  
6.6.17

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**DEKRA EXAM GmbH**  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
On the safe side.





# IECEX Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2017-06-06

Issue No.: 7

Page 2 of 4

Manufacturer: **G.M. International S.R.L.**  
Via G. Mameli 53/55  
20852 Villasanta (MB)  
Italy

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-15 : 2010** Explosive atmospheres - Part 15: Equipment protection by type of protection "n"  
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

##### Test Report:

[DE/BVS/ExTR10.0103/07](#)

##### Quality Assessment Report:

[NO/DNV/QAR07.0005/07](#)



# IECEX Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2017-06-06

Issue No.: 7

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### Type Code

Relay Output with Diagnostic type: D5293S, D5293S-xxx, D5294S, D5294S-xxx, D5295S, D5295S-xxx,  
(Option 'xxx' = non Ex-relevant details of construction or function)

#### Description

The Relay Outputs with diagnostic type D5293S, D5293S-xxx, D5294S, D5294S-xxx, D5295S, D5295S-xxx, are designed as EPL Gc equipment, which does not provide any intrinsically safe circuits and are intended for installation inside enclosures, complying with IEC 60079-15.

Electronic components of the Relay Outputs are arranged on a printed-circuit-board (PCB) packaged in a plastic enclosure suitable for installation on T35 DIN Rails or alternatively on Termination Boards.

Listing of all components used referring to older standards: not applicable.

#### Rating

See Annex

#### SPECIFIC CONDITIONS OF USE: YES as shown below:

The Relay Outputs type D5293S, D5293S-xxx, D5294S, D5294S-xxx, D5295S, D5295S-xxx shall be installed inside an enclosure, which is in accordance with IEC 60079-15.

Conditions of Use dealing with previous models, subject to issue 00 to issue 06 remain valid without change.



# IECEX Certificate of Conformity

Certificate No.: IECEx BVS 10.0072X

Date of Issue: 2017-06-06

Issue No.: 7

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Circuitry of D5293S, D5293S-xxx, D5294S, D5294S-xxx, D5295S, D5295S-xxx has been subjected to some internal changes.  
Previous issues of the CoC, dealing with models of type series DIN Rail Isolator D5\*\*\* / D5\*\*\*\*-xxx other than D5293S, D5293S-xxx, D5294S, D5294S-xxx, D5295S, D5295S-xxx remain valid.



**Certificate No.:** IECEx BVS 10.0072X, Issue 7  
**Annex**  
**Page 1 of 1**

## Rating

### 1 Power supply circuit

Relay Output type	Voltage	Power consumption
	$U_n$	$P_n$
	DC [V]	[W]
D5293S, D5293S-xxx	24 (21.6...27.6)	1.1
D5294S, D5294S-xxx		1.2
D5295S, D5295S-xxx		1.2

### 2 Relay contacts

Contact rating D5293S, D5294S, D5295S <sup>1)</sup>			
Voltage $U_n$	AC 250 V	DC 250 V	DC 30 V
Current $I_{load}$ <sup>2)</sup>	≤ 5 A	≤ 0.2 A <sup>3)</sup>	≤ 4 A
Power <sup>2)</sup>	≤ 1000 VA	<sup>3)</sup>	≤ 120 W
Remarks: <sup>1)</sup> D529*S parameters refer also to D529*S-xxx models <sup>2)</sup> resistive load <sup>3)</sup> see detailed data sheet			

### 3 Fault signal output

Single channel contact rating	D5293S, D5294S, D5295S <sup>1)</sup>	
	Output 1	Output 2
rated AC voltage	30 V	250 V
rated AC current	500 mA	3 A
rated AC Power	15 VA	750 VA
rated DC voltage	50 V	125 V
rated DC Current	500 mA	3 A
rated DC Power	25 W <sup>2)</sup>	120 W <sup>2)</sup>
Remarks: <sup>1)</sup> D529*S parameters refer also to D529*S-xxx models <sup>2)</sup> resistive load		

### 4 Ambient temperature range $-40\text{ °C} \leq T_a \leq +70\text{ °C}$